

JBRF 3L/S PFAS Water Treatment Plant

Summary of water sampling results for November 2022

Sampling of PFAS concentration levels in micrograms per litre ($\mu\text{g/L}$)

Date	PFOS Levels		PFHxS Levels		PFOA Levels	
	Untreated Water	Treated Water	Untreated Water	Treated Water	Untreated Water	Treated Water
16-11-22	5.84	<0.01	2.62	<0.01	0.14	<0.01
23-11-22	6.42	<0.01	4.17	<0.01	0.18	<0.01
30-11-22	9.75	<0.01	4.31	<0.01	0.20	<0.01

Results highlighted if Treated Water concentration is above the relevant Health Based Guidance Value.

JBRF 3L/S PFAS Water Treatment Plant

Summary of water sampling results for December 2022

Sampling of PFAS concentration levels in micrograms per litre ($\mu\text{g/L}$)

Date	PFOS Levels		PFHxS Levels		PFOA Levels	
	Untreated Water	Treated Water	Untreated Water	Treated Water	Untreated Water	Treated Water
07-12-22	27.00	<0.01	3.38	<0.01	0.20	<0.01

Results highlighted if Treated Water concentration is above the relevant Health Based Guidance Value.

JBRF 3L/S PFAS Water Treatment Plant

Summary of water sampling results for January 2023

Sampling of PFAS concentration levels in micrograms per litre ($\mu\text{g/L}$)

Date	PFOS Levels		PFHxS Levels		PFOA Levels	
	Untreated Water	Treated Water	Untreated Water	Treated Water	Untreated Water	Treated Water
04-01-23	3.80	<0.01	1.40	<0.01	0.07	<0.01
11-01-23	8.56	<0.01	3.45	<0.01	0.18	<0.01
24-01-23	9.24	<0.01	4.85	<0.01	0.17	<0.01

Results highlighted if Treated Water concentration is above the relevant Health Based Guidance Value.

JBRF 3L/S PFAS Water Treatment Plant

Summary of water sampling results for February 2023

Sampling of PFAS concentration levels in micrograms per litre ($\mu\text{g/L}$)

Date	PFOS Levels		PFHxS Levels		PFOA Levels	
	Untreated Water	Treated Water	Untreated Water	Treated Water	Untreated Water	Treated Water
01-02-23	6.03	<0.01	4.30	<0.01	0.17	<0.01
08-02-23	2.57	<0.01	1.57	<0.01	0.06	<0.01
15-02-23	6.30	<0.01	4.00	<0.01	0.18	<0.01
22-02-23	3.46	<0.01	1.97	<0.01	0.09	<0.01

Results highlighted if Treated Water concentration is above the relevant Health Based Guidance Value.

JBRF 3L/S PFAS Water Treatment Plant

Summary of water sampling results for March 2023

Sampling of PFAS concentration levels in micrograms per litre ($\mu\text{g/L}$)

Date	PFOS Levels		PFHxS Levels		PFOA Levels	
	Untreated Water	Treated Water	Untreated Water	Treated Water	Untreated Water	Treated Water
01-03-23	6.68	<0.01	4.36	<0.01	0.19	<0.01
08-03-23	10.70	<0.01	2.73	<0.01	0.19	<0.01
15-03-23	7.00	<0.01	3.87	<0.01	0.17	<0.01
22-03-23	4.79	<0.01	3.01	<0.01	0.13	<0.01
29-03-23	5.46	<0.01	4.26	<0.01	0.19	<0.01

Results highlighted if Treated Water concentration is above the agreed criterion.

JBRF 3L/S PFAS Water Treatment Plant

Summary of water sampling results for April 2023

Sampling of PFAS concentration levels in micrograms per litre ($\mu\text{g/L}$)

Date	PFOS Levels		PFHxS Levels		PFOA Levels	
	Untreated Water	Treated Water	Untreated Water	Treated Water	Untreated Water	Treated Water
05-04-23	6.57	<0.01	3.22	<0.01	0.15	<0.01
12-04-23	6.79	<0.01	3.79	<0.01	0.19	<0.01
19-04-23	7.24	<0.01	3.68	<0.01	0.16	<0.01
27-04-23	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01

Results highlighted if Treated Water concentration is above the agreed criterion.

JBRF 3L/S PFAS Water Treatment Plant

Summary of water sampling results for May 2023

Sampling of PFAS concentration levels in micrograms per litre ($\mu\text{g/L}$)

Date	PFOS Levels		PFHxS Levels		PFOA Levels	
	Untreated Water	Treated Water	Untreated Water	Treated Water	Untreated Water	Treated Water
03-05-23	2.96	<0.01	1.63	<0.01	0.09	<0.01
10-05-23	1.34	<0.01	0.53	<0.01	0.03	<0.01
23-05-23	4.49	<0.01	2.78	<0.01	0.16	<0.01
30-05-23	3.60	<0.01	2.52	<0.01	0.13	<0.01

Results highlighted if Treated Water concentration is above the agreed criterion.

JBRF 3L/S PFAS Water Treatment Plant

Summary of water sampling results for June 2023

Sampling of PFAS concentration levels in micrograms per litre ($\mu\text{g/L}$)

Date	PFOS Levels		PFHxS Levels		PFOA Levels	
	Untreated Water	Treated Water	Untreated Water	Treated Water	Untreated Water	Treated Water
06-06-23	4.90	<0.01	2.13	<0.01	0.12	<0.01
13-06-23	10.20	<0.01	3.40	<0.01	0.20	<0.01

Results highlighted if Treated Water concentration is above the agreed criterion.

JBRF 3L/S PFAS Water Treatment Plant

Summary of water sampling results for July 2023

No samples were collected through July 2023 due to 0L volume treated this month